



# Attestation of Conformity

## Unscreened Category 6 ISO/IEC, EN & TIA/EIA Connecting Hardware

**Brand-Rex Identification P/N C6C PNL U 24 012M rev E**

**Category 6, Unscreened, Patch Panel  
Electrical Transmission Performance**

**Brand-Rex Limited  
Viewfield Industrial Estate, Glenrothes  
Fife KY6 2RS, Scotland**

**Attestation of Conformity No. 103333**

*This Unscreened ISO/IEC, EN & TIA/EIA Connecting Hardware having board identification "4302 10213 Rev 1a" has been tested by 3P Third Party Testing and complies with the Category 6 transmission requirements of 2nd edition ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1, ANSI/TIA/EIA Generic Cabling Standard 568-B.2-1 and IEC Draft Connecting Hardware Standard 60603-7-4. The mated pair requirements are passed using the complete specified de-embedded range of RJ 45 plugs. The Attestation of Conformity is valid for the actually tested connecting hardware sample and no verification of the running production is performed.*

Hoersholm, 27 January 2003

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 27 January 2003

*Paul Villien*

Poul Villien  
Coordinating Manager