

## ( (

**Product:** 

## **Declaration of Conformity**

 $(\epsilon$ 

For	the following	
equipment :		

## UNINTERRUPTIBLE POWER SUPPLY ( UPS )

UPS ERA PLUS 600 CODE:	FGCERAPL602SCH
	FGCERAPL602UNI
	FGCERAPL602IEC
UPS ERA PLUS 800 CODE:	FGCERAPL802SCH
	FGCERAPL802UNI
	FGCERAPL802IEC
UPS ERA PLUS 950 CODE:	FGCERAPL952SCH
	FGCERAPL952UNI
	FGCERAPL952IEC
UPS ERA PLUS 1200 CODE:	FGCERAPL1202SCH
	FGCERAPL1202UNI
	FGCERAPL1202IEC
UPS ERA PLUS 1600 CODE:	FGCERAPL1602SCH
	FGCERAPL1602UNI
	FGCERAPL1602IEC
UPS ERA PLUS 2100 CODE:	FGCERAPL2102IEC
	FGCERAPL2102UNI
UPS ERA PLUS 2600 CODE:	FGCERAPL2602IEC
	FGCERAPL2602UNI

**Company Name:** TECNOWARE S.r.l..

**Company Address:** Via Montetrini 2/E 50065 Molino del Piano

Pontassieve (FI) ITALY

Tecnoware confirms that the equipments specified above comply with the requirements set out in: the Low Voltage Directive (Safety) 2014/35/EU and following amendments, the EMC (Electro-Magnetic Compatibility) Directive 2014/30/EU and following amendments, the RoHS Directive 2011/65/EU and following amendments.

(Date)

The following standards were applied:

(Place)

Low Voltage Directive (Safety): IEC EN62040-1

EMC Directive (Electro-Magnetic Compatibility): IEC EN62040-2

RoHS Directive: EN 50581:2012, EN 62321:2009

TECNOWARE S.r.l.
Via Montetrini, 2/E - fraz. Molino del Piano
50065 Pontassieve (Firenze)
Tel. 055 8840400 - Fax 055 8367457
Partita IVA 0 3 8 3 1 0 7 0 4 8 1

Pontassieve 10 May 2023

(Company stamp and legal Signature)